


**KN5025LC**  
DRENCH HOSE UNIT, WALL MOUNTED, WITH LOCKING CLIP



UNITS (EXCEPT THOSE WITH SELF-CLOSING VALVES) COMPLY WITH THE REQUIREMENTS OF ANSI Z358.1. TEST ALL EMERGENCY EQUIPMENT AT LEAST WEEKLY.

Drawing Number:     K301-250     Approved: \_\_\_\_\_ Revision Number:     082304-TPS